

ONTARIO FIRE DEPARTMENT CORRECTION NOTICE

Business Name: KONI HANNOONA

Date: 10/17/24

Business Address: 317 N EUCLID AVE -

File #

PAGE _____ of _____

ADDITIONAL CORRECTIONS

CLEAR

10/17/24 - SEVERAL OVERSPACED AREAS UPSTAIRS AND DOWNSTAIRS W/ FIRE SPRINKLER SYSTEM.
- SEVERAL PAINTED HEADS ON SYSTEM.
- SEVERAL HEADS MISSING ESCUTCHEONS.
- CONTACT LICENSED SPRINKLER CONTRACTOR TO SUBMIT PLANS FOR ~~NEW~~ WORK/CHANGES.

6/23/25 - WHEN POWER IS RESTORED, SCHEDULE FIRE FINAL.

A re-inspection will be held on or after _____ . Failure to have corrections made by the stated date will result in a notice of violation including a fine of \$120. If you have any questions please call (909) 395-2029. ☐ Mail Back Card Given

Fire Department Representative

Occupant Name (print)

Occupant Signature

